



State of Louisiana
Louisiana Department of Health
Office of Public Health

January 6, 2026

To: Roseland Water System (LA1105022)
Attn: Mccoy, Wanda "yodie"
P. O. Box 302
Roseland LA 70456

Re: Chemical Analysis Conducted by Pace Analytical Services, Inc.

This letter is to acknowledge that the Louisiana Office of Public Health (OPH) – Engineering Services has received and reviewed the attached drinking water monitoring results. Water samples were collected from the above supply system by Regional OPH staff and were submitted to Pace Analytical Services, Inc. for analysis.

Please review and retain the enclosed results for your water system. Results that were less than the Laboratory's Minimum Detection Limit (MDL) are indicated by a less than sign (<) preceding the reported result. A result less than the Laboratory's MDL equates to a Non-Detection. Per 40 CFR §141.33, records of chemical analyses must be retained for a minimum of 10 years.

Report Summary:

Sample ID	Sample Date	Point of Collection
35003862001	12/15/2025	Tillman Road Tp (9PTT)

Flagged Sample(s): No flagged samples are in this report.

Sincerely,

A handwritten signature in black ink, appearing to read "Sean Nolan".

Sean Nolan, P.E.
Safe Drinking Water Program

cc: R9 Office
cc: R2 Office



ANALYTICAL RESULTS

Project: LDH/OPH/Engineering R9 VOCs
Pace Project No.: 35003862

Sample: LA1105022 9PTT TP001 Lab ID: 35003862001 Collected: 12/15/25 15:50 Received: 12/17/25 11:55 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Ormond Beach									
Benzene	<0.40	ug/L	0.50	0.40	1		12/19/25 23:31	71-43-2	
Carbon tetrachloride	<0.36	ug/L	0.50	0.36	1		12/19/25 23:31	56-23-5	
Chlorobenzene	<0.31	ug/L	0.50	0.31	1		12/19/25 23:31	108-90-7	
1,2-Dichlorobenzene	<0.40	ug/L	0.50	0.40	1		12/19/25 23:31	95-50-1	
1,4-Dichlorobenzene	<0.33	ug/L	0.50	0.33	1		12/19/25 23:31	106-46-7	
1,2-Dichloroethane	<0.30	ug/L	0.50	0.30	1		12/19/25 23:31	107-06-2	
1,1-Dichloroethene	<0.37	ug/L	0.50	0.37	1		12/19/25 23:31	75-35-4	
cis-1,2-Dichloroethene	<0.33	ug/L	0.50	0.33	1		12/19/25 23:31	156-59-2	
trans-1,2-Dichloroethene	<0.33	ug/L	0.50	0.33	1		12/19/25 23:31	156-60-5	
1,2-Dichloropropane	<0.44	ug/L	0.50	0.44	1		12/19/25 23:31	78-87-5	
Ethylbenzene	<0.37	ug/L	0.50	0.37	1		12/19/25 23:31	100-41-4	
Methylene Chloride	<0.46	ug/L	1.0	0.46	1		12/19/25 23:31	75-09-2	
Styrene	<0.27	ug/L	0.50	0.27	1		12/19/25 23:31	100-42-5	
Tetrachloroethene	<0.41	ug/L	0.50	0.41	1		12/19/25 23:31	127-18-4	
Toluene	<0.28	ug/L	0.50	0.28	1		12/19/25 23:31	108-88-3	
1,2,4-Trichlorobenzene	<0.35	ug/L	0.50	0.35	1		12/19/25 23:31	120-82-1	
1,1,1-Trichloroethane	<0.29	ug/L	0.50	0.29	1		12/19/25 23:31	71-55-6	
1,1,2-Trichloroethane	<0.34	ug/L	0.50	0.34	1		12/19/25 23:31	79-00-5	
Trichloroethene	<0.26	ug/L	0.50	0.26	1		12/19/25 23:31	79-01-6	
Vinyl chloride	<0.41	ug/L	0.50	0.41	1		12/19/25 23:31	75-01-4	
Xylene (Total)	<0.42	ug/L	1.0	0.42	1		12/19/25 23:31	1330-20-7	
Surrogates									
4-Bromofluorobenzene (S)	93	%	70-130		1		12/19/25 23:31	460-00-4	
Toluene-d8 (S)	101	%	70-130		1		12/19/25 23:31	2037-26-5	
1,2-Dichlorobenzene-d4 (S)	100	%	70-130		1		12/19/25 23:31	2199-69-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LDH/OPH/Engineering R9 VOCs
Pace Project No.: 35003862

Sample: LA1105022 TCR-002 Lab ID: 35003862002 Collected: 12/15/25 16:35 Received: 12/17/25 11:55 Matrix: Drinking Water
DS0950

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Ormond Beach									
Benzene	<0.40	ug/L	0.50	0.40	1		12/19/25 23:55	71-43-2	
Carbon tetrachloride	<0.36	ug/L	0.50	0.36	1		12/19/25 23:55	56-23-5	
Chlorobenzene	<0.31	ug/L	0.50	0.31	1		12/19/25 23:55	108-90-7	
1,2-Dichlorobenzene	<0.40	ug/L	0.50	0.40	1		12/19/25 23:55	95-50-1	
1,4-Dichlorobenzene	<0.33	ug/L	0.50	0.33	1		12/19/25 23:55	106-46-7	
1,2-Dichloroethane	<0.30	ug/L	0.50	0.30	1		12/19/25 23:55	107-06-2	
1,1-Dichloroethene	<0.37	ug/L	0.50	0.37	1		12/19/25 23:55	75-35-4	
cis-1,2-Dichloroethene	<0.33	ug/L	0.50	0.33	1		12/19/25 23:55	156-59-2	
trans-1,2-Dichloroethene	<0.33	ug/L	0.50	0.33	1		12/19/25 23:55	156-60-5	
1,2-Dichloropropane	<0.44	ug/L	0.50	0.44	1		12/19/25 23:55	78-87-5	
Ethylbenzene	<0.37	ug/L	0.50	0.37	1		12/19/25 23:55	100-41-4	
Methylene Chloride	<0.46	ug/L	1.0	0.46	1		12/19/25 23:55	75-09-2	
Styrene	<0.27	ug/L	0.50	0.27	1		12/19/25 23:55	100-42-5	
Tetrachloroethene	<0.41	ug/L	0.50	0.41	1		12/19/25 23:55	127-18-4	
Toluene	<0.28	ug/L	0.50	0.28	1		12/19/25 23:55	108-88-3	
1,2,4-Trichlorobenzene	<0.35	ug/L	0.50	0.35	1		12/19/25 23:55	120-82-1	
1,1,1-Trichloroethane	<0.29	ug/L	0.50	0.29	1		12/19/25 23:55	71-55-6	
1,1,2-Trichloroethane	<0.34	ug/L	0.50	0.34	1		12/19/25 23:55	79-00-5	
Trichloroethene	<0.26	ug/L	0.50	0.26	1		12/19/25 23:55	79-01-6	
Vinyl chloride	<0.41	ug/L	0.50	0.41	1		12/19/25 23:55	75-01-4	
Xylene (Total)	<0.42	ug/L	1.0	0.42	1		12/19/25 23:55	1330-20-7	
Surrogates									
4-Bromofluorobenzene (S)	93	%	70-130		1		12/19/25 23:55	460-00-4	
Toluene-d8 (S)	101	%	70-130		1		12/19/25 23:55	2037-26-5	
1,2-Dichlorobenzene-d4 (S)	100	%	70-130		1		12/19/25 23:55	2199-69-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.